

Date	Time Meter Read	Meter Reading (1000 gal)	Water Treated (1000 gal)	CHLORINATION												FLUORIDATION					POLY-PHOSPHATES (OTHER CHEMICAL FEED)					REMARKS		
				PRE-CHLORINATION			POST-CHLORINATION			FINISHED WATER						FLUORIDE DOSAGE			TESTS mg/l		(PLEASE INDICATE ABOVE)							
				CHLORINE DOSAGE			CHLORINE DOSAGE			CHLORINE TESTS (mg/l)																		
				Reading	Amount Used lbs or ¹ Gallon	Calcul. mg/l	Reading	Amount Used lbs. Or ² Gallons	Calcul. mg/l	Time	Read	Time	Read	Time	Read	Time	Read	Time	Read	Reading	Amount Used lbs or ³ Gallons	Calcul. mg/l	Plant	Service	Reading		Amount Used lbs or ⁴ Gallons	Calcul. mg/l
a	b	c	d	e	f	g	h	k	l	m	n	o	p	r	s	t	u	v	w	x	y	z	aa	bb	cc	dd	ee	ff
0	830	74469	187000					8.00	5.13	835	1.49	1.29						1.00	0.13	0.90			11.00	2.40	1.08	0.98		
1	835	74660	191000					6.00	3.77	840	1.50	1.29						2.00	0.25	0.71			12.00	2.56	0.96	1.04		
2	935	74869	209000					10.00	5.74	940	1.36	1.13						2.00	0.23	0.82			8.00	1.56	0.90	1.02		
3	730	75056	187000					6.00	3.85	735	1.51	1.26						2.00	0.25	0.74			8.00	1.74	0.92	1.04		
4	810	75256	200000					10.00	6.00	815	1.48	1.26						1.00	0.12	0.92			12.00	2.45	1.04	1.09		
5	810	75474	218000					8.00	4.40	815	1.50	1.27						1.00	0.11	0.92			10.00	1.87	0.95	1.02		
6	735	75642	168000					7.00	5.00	740	1.36	1.17						1.00	0.14	0.94			11.00	2.67	1.06	1.05		
7	810	75814	172000					10.00	6.97	815	1.35	1.12						1.00	0.14	0.92			8.00	1.90	1.07	0.90		
8	735	76029	215000					8.00	4.46	740	1.30	1.14						2.00	0.22	0.85			10.00	1.90	1.02	1.02		
9	710	76220	191000					8.00	5.02	715	1.37	1.16						2.00	0.25	0.94			10.00	2.13	1.10	1.11		
10	750	76425	205000					9.00	5.26	755	1.44	1.09						2.00	0.23	0.76			10.00	1.99	1.00	1.10		
11	745	76613	188000					9.00	5.74	750	1.43	1.14						2.00	0.25	0.76			9.00	1.95	0.98	1.03		
12	800	76842	229000					9.00	4.71	805	1.48	1.16						3.00	0.31	0.79			12.00	2.14	1.18	1.18		
13	740	77036	194000					8.00	4.94	745	1.40	1.19						2.00	0.24	0.79			12.00	2.52	1.05	1.02		
14	750	77189	153000					9.00	7.05	755	1.37	1.14						2.00	0.31	0.75			6.00	1.60	1.04	1.15		
15	800	77457	268000					14.00	6.26	805	1.47	1.24						2.00	0.18	0.70			12.00	1.83	1.00	1.19		
16	800	77694	237000					11.00	5.57	805	1.30	1.22						2.00	0.20	0.83			11.00	1.89	1.06	0.94		
17	805	77867	173000					9.00	6.24	810	1.30	1.21						2.00	0.27	0.80			9.00	2.12	0.97	1.14		
18	805	78066	199000					8.00	4.82	810	1.27	1.19						2.00	0.24	0.76			10.00	2.05	1.00	1.11		
19	835	78278	212000					9.00	5.09	840	1.27	1.23						1.00	0.11	0.88			12.00	2.31	1.09	1.07		
20	850	78474	196000					9.00	5.51	855	1.29	1.22						2.00	0.24	0.91			11.00	2.29	1.00	0.96		
21	845	78659	185000					9.00	5.83	850	1.29	1.26						1.00	0.13	0.91			12.00	2.64	1.04	1.18		
22	855	78872	213000					7.00	3.94	900	1.20	1.16						1.00	0.11	0.92			9.00	1.72	1.04	1.08		
23	730	79068	196000					6.00	3.67	735	1.21	1.14						1.00	0.12	0.88			6.00	1.25	1.09	1.18		
24	725	79262	194000					7.00	4.33	730	1.37	1.14						2.00	0.24	0.91			9.00	1.89	1.10	1.07		
25	905	79468	206000					10.00	5.82	910	1.21	1.09						2.00	0.23	0.90			9.00	1.78	1.06	1.11		
26	750	79647	179000					7.00	4.69	755	1.29	1.18						2.00	0.27	0.86			11.00	2.51	1.02	0.98		
27	725	79828	181000					9.00	5.96	730	1.41	1.22						2.00	0.26	0.90			8.00	1.80	1.00	1.09		
28	740	79961	133000					6.00	5.41	745	1.28	1.24						2.00	0.36	0.92			6.00	1.84	1.05	1.13		
29	845	80173	212000					8.00	4.52	850	1.25	1.24						2.00	0.22	0.92			13.00	2.50	1.13	1.12		
30	950	80377	204000					8.00	4.70	955	1.22	1.18						2.00	0.23	0.96			7.00	1.40	0.98	1.10		
Total			5908000					254.00										53.00					293.00					
Ave.			196933.33					8.47	5.18		1.35	1.19						1.77	0.22	0.85			9.77	2.03	1.03	1.07		
Max.			268000					14.00	7.05		1.51	1.29						3.00	0.36	0.96			13.00	2.67	1.18	1.19		
Min.			133000					6.00	3.67		1.20	1.09						1.00	0.11	0.70			6.00	1.25	0.90	0.90		

*ENTER FINAL READINGS LAST MONTH 1 _____ %CL₂ SOLN FED 2 _____ % Cl₂ SOLN FED 3 _____ % F SOLN FED 4 _____ % SOLN FED (NOTE: RECORD COLUMNS C,E,H,V,AA AT SAME TIME)

<p>METER LOCATION:</p> <p>I certify that the information in this report is complete and accurate to the best of my knowledge:</p> <p><i>Buonanno</i> <u>251169999</u> REPORTED BY (SIGNATURE): Cert. Or Reg. No.</p> <p>Phone: <u>815-795-0215</u> Date Monthly Bacterials Sent: <u>11-4-2024</u></p>		<p>CHLORINATION</p> <p>TYPE OF CHLORINE USED: (CHECK ONE)</p> <p>CHLORINE GAS <input checked="" type="checkbox"/> _____ CALCIUM HYPOCHLORITE _____ % STRENGTH SODIUM HYPOCHLORITE _____ % STRENGTH</p>		<p>FLUORIDATION</p> <p>TYPE OF FLUORIDE USED: FLUORIDE TEST INSTRUMENT</p> <p><input checked="" type="checkbox"/> HYDROFLUOSILICIC ACID <input checked="" type="checkbox"/> HACK _____ TAYLOR _____ SODIUM FLUORIDE _____ HELLIGE _____ OTHER _____ SODIUM SILICOFLUORIDE <u>.60</u> mg/l NATURAL FLUORIDE _____ OTHER _____ OF RAW WATER</p>		<p>This Agency is authorized to require this information under Ill. Rev. Stat. 1979, Chapter 111 1/2, Section 1019. Disclosure of this information is required. Failure to do so may result in a civil penalty up to \$10,000.00 and an additional civil penalty up to \$1,000.00 for each day the failure continued, a fine up to \$1,000.00 and imprisonment up to one year. This form has been approved by the forms Management Center.</p>	
---	--	---	--	---	--	--	--